

Memo No:- 1325

Date:- 09/09/2024

Subject : Bacteriological Examination Report of Water Sample

| | | | |
|------------------------|---|-----------------------|-----------------------------|
| Sample ID: | KTL/03233/9/2024 | Sample Details | Date & Time |
| Sample Classification: | Private | Collected By | VIJAY KAUSHIK,7206404009 |
| Sender: | SHANTI NIKETAN SEN SEC SCHOOL PEEDAL | Collection Date | 06/09/2024 at 13:17 |
| Location :- | , vpo peedal | Received at lab | 06/09/2024 at 13:19 |
| Latitude :- | 76.353797 | Tested at Lab | 09/09/2024 |
| Longitude :- | 30.000346 | | |

Test Result (As Per BIS 10500 :2012)

| S.No. | Tested Parameter | Result | Requirement (Acceptable Limit) | Protocol Used |
|-------|---------------------------|--------|--|---------------------------------|
| 1 | Total Coliform per 100 ml | 0 | Shall not be detectable in any 100 ml sample | IS 15185:2016/ APHA 9221C; 2017 |

Remarks :-

- * The Results Given above are related to the sample as received and tested in KAITHAL lab.
- * The test report can't be regenerated in whole or part there of without written permission of Competent Authority.
- * The test report can't be used for any publicity or any legal purpose.
- * Reliability of water sample sample lies with sender/collector of water sample.
- * To check the sample report online Scan the QR Code below.

Water Sample has been found "**CONFORMING**" to Limits set in BIS10500:2012 for the tested parameters.
Based on the tested parameters,the water sample is found "**POTABLE**"



SUBHASH CHANDER,CHEMIST
PUBLIC HEALTH ENGINEERING DEPARTMENT
DISTRICT WATER TESTING LABORATORY,KAITHAL
email:-chemist.kaithal@phedharyana.gov.in

-----End of Report-----.